



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, Birbhum**  
**West Bengal Fire & Emergency Services**  
**Lalkhuti Para, Suri, Birbhum, Pin:- 731101**

Memo no.:FES/BIR/777/2016

Date: 25-08-2021

**From:**  
**Divisional Fire Officer, Birbhum**  
**West Bengal Fire & Emergency Services**

**To: MAHULA SRI RAMKRISHNAN TEACHERS TRAINING INSTITUTE**  
**VILL- MALANCHI, POST-KANACHI, TEHSIL- RAMPURHAT, DIST BIRBHUM, PIN 731216, WEST BENGAL**

**Sub: Renewal Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational at the premises no.- MAHULA SRI RAMKRISHNAN TEACHERS TRAINING INSTITUTE, over Plot No. 1447, 1448, & 1438, Khatian No.1398, J.LNo.52, at VILL- MALANCHI, POST-KANACHI, TEHSIL-RAMPURHAT, DIST BIRBHUM, W.B, PIN 731216**

This is in reference to your application no. 0125189211700021 dated 19-08-2021 regarding the Renewal Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational at the premises no.- MAHULA SRI RAMKRISHNAN TEACHERS TRAINING INSTITUTE, over Plot No. 1447, 1448, & 1438, Khatian No.1398, J.LNo.52, at VILL- MALANCHI, POST-KANACHI, TEHSIL-RAMPURHAT, DIST BIRBHUM, W.B, PIN 731216

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

- 1.Fire notice for the fighting and the evacuation from the building shall be prepared places of the building
- 2.Direction sign and of escape routes shall be displayed prominently
- 3.All staff / employes will be conversant with installed firefighting equipment of the building and to operate in the event of fire testing.
- 4.Arrangement shall be made for regular checking, testing and maintained of all fire safety installation equipment in the building to keep them in perfectly good working condition at all time.
- 5.Mock fire practice and evacuation drill be periodically with participation of all occupants of the building.
- 6.Electrical Line / meter box should be checked Regd. Electrician proper repair should be made, if required.
- 7.Always main gate is to be made free and should be engaged a person for maintenance of the gate.
8. Cooking arrangement is strictly prohibited in the building.
- 9.Every Three years a certificate is to be obtained from the West Bengal Fire & Emergency Services Department certifying about the satisfactory service, but all fire safety measure shall be checked and found ok by the authorized Vendor each year must. The performance of all life and safety arrangement and installation of the building

Divisional Fire Officer, Birbhum  
West Bengal Fire & Emergency Services

Memo No.: FES/BIR/777/2016